



Overview of Cogeneration Facility

Mark Johnson
Plant Manager
Clearway Energy Inc.
Pittsburgh, PA




- Founded in 1878
- 50 acre campus
- Approx. 4 million total building square footage




Energy Center History

- Duquesne signed an agreement with NORESKO, after facing several challenges:
- Aging equipment
- Environmental issues
- Rising Energy costs
- The partnership with NORESKO addressed these by developing the Energy Center and using the most advanced technology.



Energy Center History – Cont.

- Duquesne University and NORESKO entered into a 15 year contract Feb. 1996
- Began Operations November 1st, 1997
- Project cost was approximately \$9.6 million with NORESKO financing \$4.5 million over the life of the contract






Relationship With Local Utilities

- At the time, Duquesne Light Co. had no independent customer energy generation. This concept was fairly new to them.
- Much effort went into the process from start to finish.
- The University had to adhere to interconnection regulations.
- Led to creation of Rider 16 which is back up power supply to non-utility generators.
- Relationship over time has improved and led to adjustment of Rider 16 in 2014.

Energy Center New Equipment

- 5MW Solar Taurus 60 natural gas fired turbine
- 25,000 lb./hr. waste heat boiler (125 psi)
- Natural gas compressor 15 to 235 psi
- Condensate receiver and boiler feed water system for new and existing boilers
- Utility electric interconnect breaker/relay system
- Existing electric system upgrade
- Electronic control package for cogen and existing boilers




Energy Center New Equipment – cont.

- Two (2) 750 ton 2 stage absorption chiller
- One (1) 1000 ton 2 stage absorption chiller
- Approx. 4,000 feet of 18 inch to 6 inch chilled water campus supply and return distribution piping and controls
- Two (2) 150 HP chilled water pumps
- Two (2) 250 HP condenser water pumps
- Four (4) cooling tower cells to handle 2,500 tons
- Internal plant chilled water and condenser water piping and controls
- Complete electric and control system


Utilities In
(Variables)

#1 - Existing CHP Plant

Products
Out



Basic Combined Heat & Power



Condenser Water Spt: 70.0 F
Cooling CW Spt. Centrifugal: 70.0 F
Cooling CW Spt. Absorption: 80.0 F
Free Cooling CW Spt: 45.0 F

System Schematic

Tower Parameters:
CT Range: 4.8 F
CT Approach: 8.2 F
CT Efficiency: 36.8 %
#CT-1 Flow: 2035 gpm
#CT-1 Flow: 6106 gpm
One CT Flow: 3053 gpm

In Service Auto Stop Auto Stop In Service Auto Stop Auto Stop


CT-2 CT-3 CT-4 CT-5

100% 0% 0% 100%

Open Closed Closed Open

Auto Closed Auto Closed Auto Closed Auto Closed

CT Enable: Enable Enable
CT Manual Speed Spt:
CT Sequence: CT-2 CT-3 CT-4 CT-5
2 3 4 1
Force CT Rotation:
CT Required: 2




ECP Uptown Campus LLC





Gas Turbine



Gas Turbine



Natural Gas Boiler




Natural Gas Boiler




Natural Gas Boiler


Electric Distribution System




Duquesne Light



Steam Distribution System



Campus Chilled Water System



How do Others Compare?

Comparison To Atlantic 10 Schools				
School	Year Completed	Total Carbon Footprint	Carbon Footprint/Student	Location
Duquesne University	2012	39,203	3.92	Pittsburgh, PA
Temple University	2012	189,983	5.9	Philadelphia, PA
Xavier University	2010	32,964	6.3	Cincinnati, OH
University of Massachusetts-Amherst	2012	138,146	4.9	Amherst, MA
George Washington University	2010	124,116	6.1	Washington D.C.

Average Annual Performance

- Generator produced - 32,382,044 Kwh (86%)
- Imported from DLCO – 5,149,038 Kwh (14%)
- Turbine availability– 8,533 hours (97.5%)
- Waste heat boiler produced – 157,344 MLB (74%)
- Gas boilers produced – 56,617 MLB (26%)
- Gas turbine used – 406,766 MCF of natural gas
- Boilers used – 68,481 MCF of natural gas
- Energy center used – 14,430,034 Gal. of water

Design Scheme

- Generator to run in parallel with Duquesne Light.
- Not intended to furnish all electric.
- Design to utilize all waste heat all the time.
- Waste heat to drive absorption chillers in summer and heat campus in winter.
- Can run isolated if load is reduced.
- No black start.
- Automatic load shedding.





ENERGY STAR

2009 ENERGY STAR® AWARD
COMBINED HEAT AND POWER

Presented to

Duquesne University

By the United States Environmental Protection Agency and the
United States Department of Energy in recognition of the
significant pollution reduction and energy efficiency qualities of
the Duquesne University Energy Center.

Awarded on June 29, 2009

Kathleen Hogan
Director, Climate Protection Partnerships Division
U.S. Environmental Protection Agency

Design Scheme

- Generator to run in parallel with Duquesne Light.
- Not intended to furnish all electric.
- Design to utilize all waste heat all the time.
- Waste heat to drive absorption chillers in summer and heat campus in winter.
- Can run isolated if load is reduced.
- No black start.
- Automatic load shedding.




Why we selected Ice Storage

- Added 6000 ton/hr capacity without adding cooling towers
- Utilizes off peak electric rates
- No change in condenser loop piping
- More efficient utilization of existing equipment





28 Storage Tanks – 6000 ton hrs



Chilled Water/Ice System



Questions?

