

An aerial photograph of the University of Hawai'i campus. In the center, a large, rectangular carport structure is covered with solar panels. To the left, there is a large, modern building with a grey roof. The foreground shows a parking lot with several cars and a red car. In the background, there are more campus buildings, green fields, and a city skyline under a clear sky.

# UNIVERSITY of HAWAI'I



# Advancing toward 100 percent renewable energy

By 2019, the University of Hawai'i (UH) Maui College will be capable of producing as much energy as it consumes. A total of five UH Community College campuses will cut their fossil fuel energy consumption by the following:



MAUI  
CAMPUS



LEEWARD  
CAMPUS



HONOLULU  
CAMPUS



KAPI'OLANI  
CAMPUS




WINDWARD  
CAMPUS

Here's how UH is partnering with Johnson Controls to increase energy resiliency and self-sufficiency.



### Energy Performance Contract

More than \$79 million in savings over 20 years, guaranteed



### Solar + Storage

On-site capacity: 2.8 MW of solar PV and 13.2 MWh of battery distributed energy storage at UH Maui College, and 7.7 MW of solar PV and 28.6 MWh of battery distributed energy storage at the O'ahu UH Community College campuses



### Smart Controls

Automation to maximize comfort, control and reliability



### LED Lighting

Interior upgrades at all campuses



### HVAC Enhancements

Replace and upgrade chillers and related equipment



### Other Enhancements

Window film installation and new interior transformers at all campuses



### Deferred Maintenance

\$20 million reduction across two phases, through efficiency projects and savings



### Hands-On Learning

Further sustainability education



UNIVERSITY  
of HAWAII



# Why do Performance Contracting?

## Addresses efficiency & deferred maintenance

2018 **Hawaii** Average Price Per kWh: **28.88** cents per kwh



Hawaii  
Average:  
28.88 cents  
/kWh





UNIVERSITY  
of HAWAII®  
COMMUNITY COLLEGES

Oahu Campuses



Kapiolani  
Honolulu  
Leeward  
Windward



2012

AC/ Thermal

Controls

Solar

2015

HRS 304-119 requires  
UH to become net zero  
by January 1, 2035

2018

LED lighting

Chiller Controls

Solar + Storage

2020


Grid-Services

Resiliency & Revenue





UNIVERSITY of HAWAII\*  
**MAUI COLLEGE**



Maui Campus



2012

AC/ Thermal

Controls

Solar

2015

HRS 304-119 requires  
UH to become net zero  
by January 1, 2035

2018

LED lighting

Chiller Controls

Solar + Storage

2020

Grid-Services

Resiliency & Revenue



# Maui College: Phase 1 (2012)



UNIVERSITY of HAWAII\*  
**MAUI COLLEGE**



## **Performance Contract Efficiency financing by bond**

Backed by Guaranteed Savings stream, 20 year Guarantee

Lighting, AC, Controls

## **Automation with Smart Controls**

More comfort, control, & reliability for areas of campus touched by project

## **Solar PPA Pricing**

Electricity Pricing lower than Utility projections,  
20 year term

## **800kw Solar PV**

Clean Solar Energy to the grid

## **500 KW Energy Storage System**

# Maui College: Exceeding Guarantee



University of Hawaii Community Colleges Oahu District Energy Savings Performance Contract Summary						
Year	kWh Avoidance	kGal Avoidance	Therm Avoidance	Guaranteed Savings	Verified Savings*	Actual Savings**
1	1,150,443	2,427	744	\$391,660	\$389,618	\$515,868
2	1,578,087	2,427	875	\$471,394	\$545,243	\$666,308
3	1,579,557	2,427	978	\$497,713	\$598,491	\$666,712
4	1,589,472	2,427	862	\$525,531	\$585,522	\$548,185

THE BASIS OF THE GUARANTEE IS IN THE SCIENTIFIC MEASUREMENTS:  
KWH, KGAL, TRASH, & THERMS (AVOIDANCE AMOUNT)

**Guarantee** is..... promised amount X contract rate = **\$1,866,298**

**\*\*Actual** is..... measured amount X HECO rate = **\$2,397,073**

Actual amount exceeding Guarantee =  
**\$510,775**




# Maui College: Phase 2 Efficiency (2019)



UNIVERSITY of HAWAII\*  
MAUI COLLEGE

ECM #	Recommended Energy Conservation Measures (ECM)	Maui College
1	Interior LED Lighting and Controls	X
2	Replace interior transformers	X
3	Install Window Film	X
4	Replace outdated controls	X
5	Chiller replacements	X
6	Install new BTU submeters	X
7	Install Trash Compactor	X
8	HVAC Modifications	X
9	Roof Mount / Carport / Covered Walkway Solar PV + Energy Storage	X

## Impact of Efficiency Plus Renewables at UHMC



## The Impact of Solar plus Energy Storage

<b>3,499,200 kWh</b>	<b>2,464,764 kWh</b>	<b>2,382,518 kWh</b>	<b>82,246 kWh</b>
Existing Annual MECO Utility Consumption	MECO Consumption After Energy Efficiency Measures	New Solar PV Production	NET
<b>Baseline</b>	<b>30% efficiency</b>	<b>68% solar</b>	<b>98% total</b>

**+2 %  
safety  
factor**

**0%  
remains**

# Maui College: Phase 2 Solar + Storage



## Efficiency financing

Backed by Guaranteed Savings stream 20 year Guarantee

## Energy Storage with Smart Controls

Complete storage system

15 year performance guarantee

## Solar + Storage PPA Pricing

Demand Savings each year, 20 years

## 1.57 MW additional Solar PV

Clean Solar Energy stored on campus, 4 hours of storage

Total 13.2 MWHRS





# After Net Zero, what next?

A. Grid Services & Resiliency for the Community


B. Optimize energy assets to create additional revenue for the University

1. Storage Grid Service: Load Shedding

2. Storage Grid Service: Fast Frequency Response (FFR)

# “the duck curve” Grid Service Value Ratio

represents the relative value of the services during each day




high penetration of PV  
with no storage during  
middle of day

shift from 4:30pm to  
8:30pm maximizes grid  
service value




# UH Grid Services Participation

## UH provides 42 MWhrs of storage to grid



# OATI System Operation Center (SoC)






# Available Capacity Analysis Through Simulations


Detailed simulations analysis was performed using:

- One-year, 15-minute load data for each of UH campus
- Hourly Solar PV production forecast for each campus location
- Battery operation simulation per PPA requirements\*





# Capacity Reduce Grid Service

- Load reduction dispatch for up to 4 hours from 5:00-9:00 p.m.
- Dispatch notice is issued from 24 hrs to 10 minute in advance of an event



# Fast Frequency Response Deployment Trigger at 59.7 Hz An autonomous inverter-based operation







# Summary of Capacity Reduce Grid Service

UH BESS Capacity Reduce Estimates (kW)							
	Maui		Honolulu	Leeward	Windward	Kapiolani	Total Oahu
Annual Average	2,067		1,281	1,370	238	590	3,478
Holiday Periods	2,340	13%	1,321	1,797	348	702	4,167
Fall Semester	1,072	-48%	1,012	393	147	233	1,785
Spring Semester	1,763	-15%	1,118	1,698	291	296	3,404
							-2%


UH BESS Capacity Reduce by Campus



UH BESS Capacity Reduce by Island



# Total UH Incentives: \$5,464,023\*



\* Is a function of the actual kW/kWh services provide throughout the GSPA period

# Total UH Incentives: \$5,464,023\*

GSPA Incentive Structure		O'ahu	Maui
Capacity Build	\$/kW/Month	\$3.00	\$5.00
Capacity Reduce	\$/kW/Month	\$2.00	\$5.00
	\$/kWh	\$0.1497	\$0.1441
FFR	\$/kW/Month	\$5.00	N/A

UH BESS Incentives	Year 1	Year 2	Year 3	Year 4	Year 5	Total
Honolulu Campus	\$ 244,367	\$ 244,367	\$ 244,367	\$ 244,367	\$ 244,367	\$ 1,221,833
Leeward Campus	\$ 284,208	\$ 284,208	\$ 284,208	\$ 284,208	\$ 284,208	\$ 1,421,040
Windward Campus	\$ 132,417	\$ 132,417	\$ 132,417	\$ 132,417	\$ 132,417	\$ 662,086
Kapiolani Campus	\$ 130,190	\$ 130,190	\$ 130,190	\$ 130,190	\$ 130,190	\$ 650,952

Maui College	\$ 301,622	\$ 301,622	\$ 301,622	\$ 301,622	\$ 301,622	\$ 1,508,112
--------------	------------	------------	------------	------------	------------	--------------

Total UH Campuses	\$1,092,805	\$1,092,805	\$1,092,805	\$1,092,805	\$1,092,805	\$ 5,464,023
-------------------	-------------	-------------	-------------	-------------	-------------	--------------



# Sustainable Life & Practice (SLP)

*Learning from the sustainable life & practices of Hawaii*

*Picture: Hokule'a, Polynesian Voyaging Society*



\$264,738 per month

\$8,644 per day

Amounts paid towards utilities  
to be re-directed to  
Facility improvements  
at Maui campus  
+ all 4 Oahu campuses



Mahalo

Transforming Campus Infrastructure  
to Improve Sustainability and Energy  
Efficiency

UND  
Mr. Mike  
Pieper

CampusEnergy 2020





# University of North Dakota

## The Challenge

- Century-old coal plant at the center of campus needing immediate replacement

## The Innovative Solution **Public-Private Partnership**

*Design, Build, Finance, Operate, Maintain*

- Natural gas-fired steam plant, moved to edge of campus
- Central quad developed
- Intelligent lighting infrastructure
- Building controls upgrades
- HVAC & mechanical equipment



- 200 building campus, 6.5M sq. ft.
- 40-year public-private partnership
- Consortium members include:
  - Affiliated Engineers
  - AE2S
  - JLG Architects
  - Odney Public Affairs
  - Obermiller Nelson Engineering (ONE)
  - PCL Construction



