

Lessons in System Transformation and Resilience from Milwaukee Regional Medical Center

Mark Geronime, Milwaukee Regional Medical Center (MRMC)

Rory Peters, Ever-Green Energy









Agenda

- Who We Are
- Reconstruction Project Scope
- Added Scope
- Operational Lessons Learned
- Results









Milwaukee Regional Medical Center Thermal Service

Provide steam and chilled water for 7M sq ft of premier healthcare space

Managed by Ever-Green Energy, a subsidiary of District Energy St Paul

Campus Thermal Energy Systems

- Coal-fired CHP built by Milwaukee County in 1955
- Chilled water added in 1970s
- Purchased by the local electric utility in late 1990s

Acquired by MRMC Thermal in April 2016

- Capital investment of \$150M (2016-2019)
- Improved the reliability of critical steam and chilled water service to the hospitals and research facilities on campus
- Modernized the plant and distribution facilities to increase resiliency, reduce costs, improve efficiency, and reduce greenhouse gas emissions





Initial Configuration

DISTRIBUTION SYSTEM TO USERS

- Steam
- Condensate

MAIN PLANT


- 3 Coal Boilers 255K #/hr
- 2 Gas Boilers 148K #/hr
- 14 Chillers 20K Tons
- 3 Turbine Generators 7.5 MW
- Natural Gas Feed
- HV Electrical Feed
- No central control system

DISTRIBUTION SYSTEM TO USERS

- Steam
- Condensate
- Chilled Water

Many single points of failure

Reconstruction: Production Resiliency



Reliability through Bi-Furcation

Added Scope


- Flywheel UPS
- Chilled Water Cross-Connect
- Pre-stressed Concrete Cylinder Piping (PCCP) Inspection and Repair
- Boiler and Chiller Turbine Conversion






Flywheel UPS






112 Events Since Startup



60-80%

■ 88-112% ■ >112%



< 120 cycles</p>


> 900 cycles

120-900 cycles





Cross-Connect










PCCP Inspection and Repair



Typical LCP Cross Section

Table 2.2: Pipes with Broken Wire Wraps in the Chilled Water Lines							
Rank	Pure Reference Number	Low Station	Pipe Length (feet)	Pipe Class	Break Positional Range (feet)	Number of Broken wire wraps by Region	Total Number of Broken wire wraps
36-inch West Pipeline							
1	4009	0+94	16	N/A	2.5;4.0	15;10	25
2	4007	0+74	16	N/A	2.5;5.5	10;5	15
3	4011	1+32	16	N/A	13.5	15	15
4	9032	6+96	16	N/A	14.0	10	10
5	9007	3+16	16	N/A	14.0	5	5
6	9018	4+72	16	N/A	10.5	5	5



Longitudinal Crack observed at the invert of Pipe 8019 pipe









Boiler / Turbine Conversion

Original Process Flow



Current Process Flow



10 YEAR NPV SAVINGS FROM BOILER CONVERSION: \$1.8M





Lessons Learned

- OEM Training
- Operations Project Coordinator
- Commissioning Agent
- Service Contracts and Warranties
- Segmented Distribution





OEM Training Agenda

- Description of Operation
- Basic process flow
- General arrangement including component nomenclature
- Controls, safeties, permissives, and interlocks
- Troubleshooting
- Mechanical and Electrical isolations

Insist on using the drawings!





Project Coordinator Role

- Interface between Operations and Project Team
- Design and Specification Review
- Daily project support
 - LOTO, Hotwork, Confined Space, area access, laydown area designation, quality control, RFI development
- Startup/commissioning/problem solving support
- SOP / Maintenance Procedure Development
- Project documentation QA/QC
- Ongoing Operations training resource





Commissioning Agent Role

- Third-party confirmation of installation and testing in accordance with specification
- Design and specification review
- Startup / commissioning / problem solving support
- Project documentation collection

Get what you paid for!





Service Contracts and Warranties

- Factor a 10 year service agreement into equipment procurement as part of the LCCA
 - Service rates 30-40% higher than the same labor as install
- Guarantees on response times
- Service tech capabilities / bios
- Manufacturer vs. OEM parts
- Parts availability guarantees
- Beware the parts-only warranty
- Consider equipment run-time versus calendar-based warranties






Steam Distribution Segmentation

Initial Configuration

Existing Box Trench Existing Abovegrade Piping

New Configuration









Chilled Water Distribution Segmentation

Initial Configuration



New Configuration







Results

- Consistent, High Reliability
- Emissions Reduction
- Cost Reduction & Reinvestment





2016-2019 Reliability

- Chilled Water: 100.000%
- High Pressure Steam: 99.993%
- Low Pressure Steam: 100.000%

Combined: 99.998%

Against Contract Requirements






Emissions Reductions

CY17/18 average (42,706 mtons) is 33% of CY13-15 average (129,740 mtons)









Costs

- Member savings since acquisition estimated to be \$83M through year end 2019 (~\$2M/month)
- Real Time Market Pricing (RTMP) for electricity expected to save >15% on future electrical costs (starting in 2020)
- Hedging gas has locked in much lower rates and provides budget certainty. Savings
 >20% over daily purchase (Previous method of supplying gas)
- Favorable financing continues. Refinancing completed 2018
- No rate increase 2016 with moderate rate increases in years 2 4 and no rate increase in current year (2020)
- 2020 budgets <2019 which was <2018/2017 budgets
- Savings have exceeded original pro forma

MRMC Thermal: Member-owned since 2016





1950s VINTAGE STOKER COAL BOILERS



NEW DUAL-FUEL BOILERS



1970s VINTAGE ABSORPTION CHILLERS



NEW
CENTRIFUGAL
CHILLERS



TEMPORARY BOILER PLANT



NEW NORTH PLANT BOILERS



Questions?

Mark Geronime

mgeronime@mrmcffl.org

Rory Peters

rory.peters@ever-greenenergy.com





Thank you!



