

TRIGENERATION AT UNIVERSITY OF MINNESOTA

INSTALLATION OF A MODERN ABSORPTION CHILLER & DISPATCHING STRATEGIES




OVERVIEW




PRESENTATION TOPICS

- Background
- Why Absorption?
- Laying Out the Project
- Carbon Footprint Reduction
- End Results



UNIVERSITY STEAM AND CHILLED WATER UTILITIES

- U of MN tri-generation system
 - Multiple co-gen heating plants
 - Multiple chilled water districts
- 2017 Project: 24MW Gas Turbine with Heat Recovery
 - Centerpiece of Trigeneration System
- Academic Health Sciences
 - Largest and most consistent chilled water user
 - Campus is fully developed in this district
 - Projects are usually retrofits within existing building envelopes
 - **Outages of infrastructure in this mission critical area of campus are high impact and very infrequent**





BACKGROUND



TRI-GENERATION WITH MAIN ENERGY PLANT


- MEP began commercial operation in 2017
- CHP 101: Match thermal and electric loads
- Campus Electric Peak Demand Reduction
 - Peak demand charges ~50% of annual campus electric costs



GE LM2500 DLE Dual Fuel
220 MMBtu/hr Input (HHV) 24 MWe Generator Output



UMN Chilled Water Utilities: System Capacity & Peak Demand




Demand-Limiting Strategies

- Steam absorbers (~9,000 tons)
- Future steam turbine chillers (6,000 tons)
- Future inlet air cooling on MEP turbine (900 ton load, +2 MW output)
- Building mass thermal energy storage
- (Future) Traditional TES options, ice and/or chilled water storage


BACKGROUND



TRIGENERATION




CONVENTIONAL CHILLER



ACADEMIC HEALTH CHILLED WATER DISTRICT

UMN Health Sciences District
System Capacity & Peak Demand



Chiller Technologies

- The following chiller technologies were considered:
 - Electric centrifugal:
 - Insufficient electric feeder capacity,
 - Negative impact on campus peak electric demand charges
 - Steam turbine:
 - For this part of the system, would require staffing change, MN statute requires a licensed boiler operator on-site for start-ups
 - Absorption:
 - Peak electric demand reduction
 - Locational flexibility
 - University operators already have experience with this technology.
 - Deemed the best available technology for this application.






LAYING OUT THE PROJECT



Chiller Procurement

- Clearances: Rigging and Final Location
- Disassembly and Reassembly requirements called out to accommodate available clearances.



Chiller Selection

- Chiller RFP:
 - Pre-bid site walkthrough required for all vendors
 - Submit chiller performance (zero tolerance at full design load conditions)
 - Submit condenser and chilled water DPs
- Factory Performance Test
- On-Site Performance Test

Attachment C: Chiller Performance Guarantees

Mandatory On-Site Field Performance Demonstration Test
Actual performance data to meet or exceed submitted data in Attachment B per specified COP tolerance.


Performance Map		Evap. Delta T	Lvg Evap	Steam PPH				COP Tolerance	
Load	Tons	deg F	deg F	CND Ent. Temp. (deg F)				Upper Limit	Lower Limit
				85	80	75	70		
100.0%	1000	18	40					none	ZERO @ 85F
100.0%	1000	12	40					none	AHRI 560
80.0%	800	12	40					none	AHRI 560
60.0%	600	12	40					none	AHRI 560
40.0%	400	12	40					none	AHRI 560
Average				#DIV/0!	#DIV/0!	#DIV/0!	####		

Non-Mandatory Factory Condenser Flow Performance Test

CND Pump Energy		Evap. Delta T	Lvg Evap	CND/ABS Flow (gpm)				CND/ABS dp (ft H2O)			
Load	Tons	deg F	deg F	85	80	75	70	85	80	75	70
100.0%	1000	18	40								
100.0%	1000	12	40								
80.0%	800	12	40								
60.0%	600	12	40								
40.0%	400	12	40								
Average				#DIV/0!	#DIV/0!	#DIV/0!	####	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!

Chiller Selection



- Broad Model BS400
- Design Conditions:
 - 1,000 tons capacity
 - Evaporator: 40°/58°F
 - Condenser: 85°/97°F
 - Inlet Steam Pressure: 125 psig, saturated
 - Steam Consumption: 8,385 lb/hr
 - COP: 1.4
 - Steam powered condensate pump
- Tube Materials:
 - Evaporator: Copper
 - Condenser: Cupronickel
 - Absorber: Curponickel
 - HTG: Titanium
 - LTG: Cupronickel



LAYING OUT THE PROJECT



Equipment Install - Shaft Access




LAYING OUT THE PROJECT



Moos Tower Chiller Layout and Installation

- Laser scan was essential for adequate clearance for piping, tube pull and chiller service
- Existing single stage absorption chiller was shifted 3' to provide additional clearance
- Careful scheduling of outages, then proceeded with assembly




END RESULTS



Chiller Performance Tests

- Witness performance test done at the Broad factory in China
 - NV5 was present
- Field performance test done upon completion of installation
 - Design capacity and peak performance were tested to zero tolerance
 - Part-load performance tested based on AHRI conditions
 - Field performance and tight metering specification included in RFP for chiller for OEM reference

40% Performance Data														
Date	Time	143-CW-R208 CHW (Ton-Hour)	143-CW-R207 CHW (Ton-Hour)	143-CWFL-R206 CHW FL (Gal/Min/Hr)	143-CWFL-R207 CHW FL (Gal/Min/Hr)	143-CWRT-R206 (Temperature e, F)	143-CWRT-R207 (Temperature e, F)	143-CWRT-R208 (Temperature e, F)	143-CWRT-R209 (Temperature e, F)	143-CWRT-R210 (Temperature e, F)	143-CWRT-R211 (Temperature e, F)	143-CWRT-R212 (Temperature e, F)	143-CWRT-R213 (Temperature e, F)	COP
7/22/2019	3:00 AM	179526.91	497136.90	976.61	3165.75	53.70	83.77	42.80	77.04	6229170.90	1286.18	127.53	354.11	
7/22/2019	3:05 AM	179526.91	497136.90	976.61	3165.75	53.70	83.77	42.80	77.04	6229170.90	1286.18	127.53	354.11	
60% Performance Data														
Energy Balance														
80% Performance Data														
100% 12DT Performance Data														
100% 18DT Performance Data														
100% 18DT Field Test #1 Average*														
100% 18DT Field Test #2 Average*														
100% 18DT Rating Prg														




Chiller Operation

- Features of modern absorption chillers:
 - Modern PLC's are configured ensure the absorption machine stays out of the crystallization zone
 - Automatically limits capacity on low entering water temperature
 - Modern machines have automatic purge systems to maintain vacuum
 - Improvements in steam control valves have allowed absorbers to react better to load changes
 - Tube metallurgy (CuNi, SS, titanium) have reduced tube issues and improved reliability
- The absorbers are typically run at 80-90% load
 - Maximizes equipment life (reduced HTG temp)
 - Lower entering tower water temperature reduces absorber capacity
 - Lower tower temp improves overall plant efficiency



Lessons Learned


- Reassembly was more labor intensive than we had planned.
- Having a skilled contractor in place as a partner was key, especially given the tight physical constraints in all directions.
- We utilized a steam-powered condensate pump for this project. Finding adequate vertical clearance was a significant challenge.
- Laser scanning of the entire plant was a major time-saver in such a crowded plant
- Highly recommend detailing out each pipe support location when possible to avoid extra costs from field-routing
- Chiller delivery in -20F windchill is not fun. . .




ANNUAL CHILLER CO₂ EMISSIONS DEPENDS ON DISPATCH METHOD



TRIGENERATION



CONVENTIONAL CHILLER




*Based on utility annual average CO₂ emissions of 0.365 MT CO₂/MWh, per Xcel CO₂ Emission Intensities 2018 and chiller efficiency of average fleet efficiency 0.515 kW/ton


ANNUAL CHILLER CO₂ EMISSIONS DEPENDS ON DISPATCH METHOD



TRIGENERATION



CONVENTIONAL CHILLER




*Based on utility annual average CO₂ emissions of 0.365 MT CO₂/MWh, per Xcel CO₂ Emission Intensities 2018 and chiller efficiency of average fleet efficiency 0.515 kW/ton

ANNUAL CHILLER CO₂ EMISSIONS DEPENDS ON DISPATCH METHOD




TRIGENERATION



Using Waste Heat Only: **0.00** kg CO₂/ T-HR

CONVENTIONAL CHILLER




*Based on utility *annual average* CO₂ emissions of 0.365 MT CO₂/MWh, per Xcel CO₂ Emission Intensities 2018 and chiller efficiency of average fleet efficiency 0.515 kW/ton

END RESULTS



Moos Chiller 13 Operation vs. MEP Operation




END RESULTS



Campus Cooling CO2 Footprint Reduction

- MEP reduces UMN CO2 footprint by 25%
- Conservation measures and fuel source improvements have provided another ~15% reduction
- Venting waste steam while generating at MEP is economically favorable
- Absorption cooling with this waste heat has a **40% lower CO2 footprint and ~80% lower fuel cost** vs electric centrifugal plant
- → Abs. cooling is **a key thermal load to balance our CHP system and maximizing value**
- → **Every pound of steam saved** on campus during summer **improves cooling CO2 footprint**



QUESTIONS?



JARED SATROM, PE

Principal Mechanical Engineer
Energy Management

University of Minnesota

satr0021@umn.edu

612.625.2865

MATT WOLF, PE

Senior Mechanical Engineer

NV5

matt.wolf@nv5.com

651.634.7232